

AMEV attestation for certified BACnet devices

1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	DEOS AG		
Product name	OPEN 4100 EMS, OPEN 810 EMS, OPEN 600 EMS		
Product model number	-		
Standard device profile	B-BC	BACnet protocol vers. / rev.	1.12
Firmware revision	1.052.3		

Data link layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input checked="" type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input checked="" type="checkbox"/> MS/TP baud rates: 9600, 19200, 38400, 57600, 76800, 115200, a. o.	
	<input checked="" type="checkbox"/> PTP*)	
Static device binding	<input checked="" type="checkbox"/> Yes (for MS/TP only)	
Networking options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input checked="" type="checkbox"/> Router, medium: BACnet/IP, MS/TP, PTP	
Character sets	<input checked="" type="checkbox"/> UTF-8	
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

2. The device supports BACnet functions as per AMEV profile:

<input type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of:
<input checked="" type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of: V 1.2 29.01.2014
<input type="checkbox"/> AMEV profile	As of:

3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab MBS dated 08.04.2014 number VG 2013_8438
<input checked="" type="checkbox"/> AMEV recommendation BACnet V 1.2 As of: 29.01.2014 (see www.amev-online.de)

4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BTL-30085 (see http://www.bacnetinternational.net/btl)

*) informative, function has not been tested

Stuttgart, 25.04.2017



Dr.-Ing. Bernhard Hall,
Vermögen und Bau Baden-Württemberg
Rotebühlplatz 30
70195 Stuttgart
Telefon +49 711 6673-3433
Email Bernhard.Hall@Vbv.bwl.de

(AMEV Obmann BACnet)



WSP Cert

Dr.-Ing. Frank Bitter
Kapuzinerweg 7
D-70374 Stuttgart
Telefon +49 711 953922-0
Telefax +49 711 953922-66

(BACnet certification body)